



NOTE:

USE SERVICE SADDLE AND TAPPING SLEEVE FOR PVC RECLAIMED WATER MAINS. FOR DUCTILE IRON RECLAIMED WATER MAINS, SEE WS 2.16, 3 OF 3, FOR SADDLE REQUIREMENTS.

No. 3 VALVE BOX & LID	WS 3.11	
ITEM	CROSS REF.	SPEC. REF.